

**CITY OF LOVINGTON**



**17<sup>TH</sup> STREET RECONSTRUCTION - ADDENDUM #2**  
**BID NO. 17<sup>TH</sup> PH01-2017**

NOTICE TO BIDDERS:

1. This Addendum is issued to all registered plan holders and shall be published in all locations where the original RFB is published. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
2. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
3. Incidental Item 10 - There are fences that are within the ROW for a significant portion of the project and it is anticipated that construction activities could necessitate removal and replacement of fencing for most areas. The ROW limits are also shown on the PnP sheets as a dashed line. The existing fence is shown in relation to the ROW line.
  - a. In areas owned by the City of Lovington, the fence may be removed without replacement.
4. Incidental Item 7 – Refers to any temporary soil bracing that may be needed in soil excavation primarily for concrete structures.
5. Incidental Item 11 – Refers to waterline work that is warranted by the project. Valve /hydrant relocations will need to be capped.
6. Incidental Item 12 - Refers to the existing waterline and its laterals. The connections need to be repaired if damaged during construction.
7. Incidental Item 15 - Cast iron is acceptable for detectable warning surfaces so long as it complies with the construction drawings.
8. Incidental Item 19 - Refers to work described in General Note 31.
9. All terms, conditions, and requirements of the original project manual and construction documents shall remain in place unless explicitly mentioned in this Addendum.

By: James Williams  
City Manager

Bidder Acknowledgement:

Bidder Name \_\_\_\_\_

Date: \_\_\_\_\_